

January 25, 2024

ADDENDUM
TO THE
BID CONTRACT DOCUMENTS AND SPECIFICATIONS
FOR IFB-2024-03

Relocation of Electrical Panels and Installation of Main Breakers at Multiple Single-Family Homes located in Dallas, Texas

Clarifications, amendments, additions and/or deletions to the plans and specifications are hereby incorporated as follows:

Additions

1. Wired Combo Smoke Alarms needed in all homes associated with IFB-2024-03 installed to meet city code.
2. All existing meter bases shall be replaced, and all service risers shall be replaced at each (overhead fed) location. Contractor shall ensure that the location of electric meter meets Oncor requirements and service drops do not pass over a carport or other building structure.
3. 4635 Silversprings Drive- Aluminum Branch Circuit noted as needing to be replaced.
4. 12384 High Meadow Dr- Two pronged receptacles to be replaced throughout location.

Amendments:

5. NA

Clarifications:

1. All properties have had prior asbestos inspections done prior to acquisition.

DALLAS HOUSING AUTHORITY OF NORTH TEXAS
Pre-Bid Meeting
Sign-In Sheet

IFB-2024-03 Relocation of Electrical Panels and Installation of Main Breakers at Multiple Single-Family Homes located in Dallas,
Texas

Tuesday, January 23, 2024 @ 10:00 A.M.

NAME	COMPANY	PHONE #	FAX #	E-Mail Address
Johnny Sadigilat	TX AER XTR LMR RLCU	817-822-5662		SRVIERA@XTRLMRRLCU.COM
Charles Traugh	TX AIRS SYSTEMS	361-550-9148		charles.traugh@texasairsystems.com
David Garcia	TX AIRS SYSTEMS	817-475-3142		david.a.garcia@texasairsystems.com
Cleveland Seiv	Ampere Network	214-796-4900		cmseivoy@hotmail.com
Ty Thompson	TECHCHEFS	214-392-9099		TY@TECHCHEFS.TX.COM
Mario Gutierrez	American Builders	713-594-6405		operations@AmericanBuildersGroupLLC.com
Joseph Lomo	HCE Construction	214-387-7444		HCEConstructionGroup@gmail.com